

**FIRE SAFETY CERTIFICATE**

No. FIRE/13/JFS/2022-23/819

Dated: 03/11/2022

Certified that the KMMP SCHOOL at ON NH-25, NEAR DANGIYAWAS BY - PASS, DANGIYAWAS JODHPUR RAJASTHAN INDIA-342027 comprised of ground, first and second floors owned/ occupied by KMMP SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 18/10/2022 (date of inspection) in the presence of Mr. Sharwan Ram, Manager of KMMP SCHOOL and that the building/ premises is fit for occupancy up to classes XII With effect from 03/11/2022 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Suitable fire activator, hosiery and water storage pumping facility was found in the school premises. The pumping unit has to be kept in working condition at all times.
2. The building can be inspected by the fire officer at any time and in case the fire system is not found working, this certificate will be treated as cancelled.
3. Water tanks will have to be kept full at all times and the pump and the entire fire system will be obliged to keep it in working condition for 24 hours.
4. To run the fire system, fire trained personnel will have to be engaged for 24 hours and AMC. Maintenance and operation of the system will be mandatory after getting it done.

Issued on 03/11/2022 at Jodhpur, Rajasthan by

\*Strike out whichever is not applicable.

Signature with Seal

Name

Designation

Name &amp; Address of Department/ Office: Jodhpur

*[Signature]*  
03.11.22  
मुख्य अ. अधिकारी  
नगर निगम जोधपुर  
: Chief Fire Officer

To,

The Chairman

KMMP SCHOOL

ON NH-25, NEAR DANGIYAWAS BY - PASS,

DANGIYAWAS JODHPUR RAJASTHAN INDIA-342027

**ENDORSEMENT**

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....(reasons to be recorded).

(Name and designation of the authorized signatory)